

**From:** Catherine Sotelo  
**To:** [Mason, Steve](#)  
**Subject:** Re: Arkema Crosby Plant (TX) Inundation/Potential Fire  
**Date:** Tuesday, August 29, 2017 7:27:42 AM  
**Attachments:** [image001.png](#)

---

Steve,

Unfortunately all the numbers were busy **but** I did get a call from Ms. Jean Marie Cencetti (Director of Env. and Sustainable Development for Arkema; 610-878-6632) at 0632 hours today. She provided me with an update. Facility is out of power but has diesel powered cooling trailers and enough fuel to cool for 6 days.

There is no offsite discharge or fire at this time. Rideout crew (10 personnel) have boats to leave site if necessary. The did provide an update to David Wade (LEPC POC) last night to inform him of the facility's situation.

Additionally, I believe I may have found an article regarding the Northern Houston water treatment plant you were referring to? <http://www.chron.com/news/houston-texas/houston/article/City-working-to-keep-operating-water-plant-12112233.php>

If you are still needing information please feel free to contact me (b) (6) and I'll poke around for information.

All the best,

**Catherine Sotelo**

**Emergency Response Coordinator**

**Texas Commission on Environmental Quality**

**Region 12 • Houston • Waste Section**

**Main: 713-767-3700 • Direct: 713-767-3617 • Fax: 713-767-3761**

---

**From:** Mason, Steve  
**Sent:** Tuesday, August 29, 2017 5:47:26 AM  
**To:** Catherine Sotelo  
**Subject:** RE: Arkema Crosby Plant (TX) Inundation/Potential Fire  
Arkema Emergency Contact Name: Wendal Turley  
Emergency Contact Title: Plant Manager  
Emergency Contact Phone: (281) 328-9443  
Emergency Contact 24-Hour Phone: (281) 328-9447

## Facility Contact Information

Name	Contact Type	Phone	Email
Stacy Dorsey	Emergency Contact	Work - 281-328-9422 24-hour - 281-328-9447	stacy.dorsey@arkema.com



9796849

Stacy Dorsey	Fac. Emergency Coordinator	<b>Work</b> - 281-328-9422 <b>24-hour</b> - 281-328-9447	stacy.dorsey@arkema.com
ARKEMA Inc	Facility Phone	<b>FP</b> - 2813289447	
Wendal Turley	Owner / Operator	<b>Work</b> - (281) 328-9443	wendal.turley@arkma.com
Carolyn Hervey	Submitter	<b>24-hour</b> - 281-328-9447 <b>Work</b> - 281-328-9430	carolyn.hervey@arkema.com
Carolyn Hervey	Tier II Information Contact	<b>24-hour</b> - 281-328-9447 <b>Work</b> - 281-328-9430	carolyn.hervey@arkema.com

**With Regards, Steve**



**From:** Catherine Sotelo [mailto:Catherine.Sotelo@Tceq.Texas.Gov]

**Sent:** Tuesday, August 29, 2017 5:20 AM

**To:** Mason, Steve

**Subject:** Arkema Crosby Plant (TX) Inundation/Potential Fire

Good Morning Steve,

I was just looking for point of contact's for the Arkema Crosby Plant facility .

I have tried phone numbers for Crosby FD, Crosby Volunteer FD, Harris County OEM, David Wade (Greater Harris County LEPC Industrial POC/OEM Member), Crosby Fire Marshall, Harris County Pollution Control Services, and Arkema General ER Media Relations, to get information however, it's been very difficult to get facility point of contact information or at the very least, general situational awareness.

We haven't received any notifications via NRC or SERC regarding this facility in the past few days since Hurricane Harvey.

Here is a link to the article from which I became aware of the situation:

<http://www.chron.com/neighborhood/humble/news/article/Reports-of-chemical-plant-emergency-in-Crosby-12123269.php>



**[Workers reportedly trapped inside flooded chemical plant in Crosby](http://www.chron.com/neighborhood/humble/news/article/Reports-of-chemical-plant-emergency-in-Crosby-12123269.php)**

[www.chron.com](http://www.chron.com)

Twelve workers were reportedly trapped early Tuesday morning at a Crosby chemical plant on the brink of catching fire as firefighters were on the way, according to the wife of one of the workers.

Thank you!

**Catherine Sotelo**

Emergency Response Coordinator

Texas Commission on Environmental Quality

Region 12 • Houston • Waste Section

Main: 713-767-3700 • Direct: 713-767-3617 • Fax: 713-767-3761